

## **Information requirements (air-to-air air conditioners)**

**Information requirements  
(heat pump)**

Model(s): DC-42KDBS(W) 、 DOX-42KDBS(W)							
Outdoor side heat exchanger of heat pump	air						
Indoor side heat exchanger of heat pump	air						
Indication if the heater is equipped with a supplementary heater	no						
If applicable: driver of compressor	electric motor						
Parameters declared for	Average climate condition						
Item	symbol	value	unit	Item	symbol	value	unit
Rated heating capacity	P <sub>rated,h</sub>	13,5	kW	Seasonal space heating energy efficiency	η <sub>s,h</sub>	170,0	%
Declared heating capacity for part load at indoor temperature 20 °C and outdoor temperature T <sub>j</sub>	Declared coefficient of performance for part load at given outdoor temperatures T <sub>j</sub>						
T <sub>j</sub> = - 7 °C	Pdh	7,64	kW	T <sub>j</sub> = - 7 °C	COP <sub>d</sub>	2,68	-
T <sub>j</sub> = + 2 °C	Pdh	4,14	kW	T <sub>j</sub> = + 2 °C	COP <sub>d</sub>	4,28	-
T <sub>j</sub> = + 7 °C	Pdh	2,81	kW	T <sub>j</sub> = + 7 °C	COP <sub>d</sub>	5,78	-
T <sub>j</sub> = + 12 °C	Pdh	2,96	kW	T <sub>j</sub> = + 12 °C	COP <sub>d</sub>	7,18	-
T <sub>biv</sub> = bivalent temperature	Pdh	7,64	kW	T <sub>biv</sub> = bivalent temperature	COP <sub>d</sub>	2,68	-
T <sub>OL</sub> = operation limit	Pdh	6,24	kW	T <sub>OL</sub> = operation limit	COP <sub>d</sub>	2,70	-
T <sub>j</sub> = - 15 °C (if TOL < - 20 °C)	Pdh	NA	kW	T <sub>j</sub> = - 15 °C (if TOL < - 20 °C)	COP <sub>d</sub>	NA	-
Bivalent temperature	T <sub>biv</sub>	-7,00	°C	Operation limit temperature	T <sub>ol</sub>	-10,00	°C
Degradation co-efficient heat pumps(***)	C <sub>dh</sub>	0,25	—				
Power consumption in modes other than 'active mode'				Supplementary heater			
Off mode	P <sub>OFF</sub>	0,008	kW	Back-up heating capacity (*)	elbu	2,260	kW
Thermostat-off mode	P <sub>TO</sub>	0,017	kW	Type of energy input			
Crankcase heater mode	P <sub>CK</sub>	0,000	kW	Standby mode	P <sub>SB</sub>	0,008	kW
Other items							
Capacity control	variable			air flow rate, outdoor measured	—	5200	m <sup>3</sup> /h
Sound power level, indoor/outdoor measured	L <sub>WA</sub>	66/73	dB				
Emissions of nitrogen oxides (if applicable)	NOx(***)	-	mg/kWh input GCV	Rated brine or water flow rate, outdoor side heat exchanger	—	-	m <sup>3</sup> /h
GWP of the refrigerant	675		kg CO <sub>2</sub> eq (100 years)				
Contact details: sat.eurofredgroup.com.				Name and address of the supplier: EUROFRED S.A. C/ Marques de Sentmenat, 97 08029 Barcelona, Spain			

(\*)

(\*\*) If Cd<sub>h</sub> is not determined by measurement then the default degradation coefficient of heat pumps shall be 0,25.

(\*\*\*) From 26 September 2018.

Where information relates to multi-split heat pumps, the test result and performance data may be obtained on the basis of the performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.



66329902229